

SCOPE SCHEMATIC

LEGEND		
NR		NON RETURN VALVE
BV		BALANCING VALVE
IV		ISOLATION VALVE
HWM		HOT WATER METER
CW		COLD WATER
HWF		HOT WATER FLOW
HWR		HOT WATER RETURN
TW		TEMPERED WATER
SCP		SECONDARY CIRCULATION PUMPS
A/P		ACCESS PANEL
T		TEMPERING VALVE
PRV		PRESSURE REDUCTION VALVES

- NOTES:**
- DO NOT PLACE PRVS ON HOTWATER CIRCULATION LINES
 - ALL HOTWATER RETICULATION PIPEWORK TO BE COPPER, STAINLESS STEEL OR REHAU. CHECK WITH MANUFACTURER FOR CONTINUOUS HOTWATER TEMPERATURE OPERATION FOR SUITABILITY.
 - COMMET CAN ONLY BE USED FOR EMBEDDED NETWORK SYSTEMS. PLEASE CHECK WITH EMBEDDED NETWORK PROVIDER PRIOR TO INSTALLING PRODUCT FOR COMPATIBILITY.
 - WHEN CALCULATING PUMP DUTY ENSURE TO CONSIDER RESISTANCE OF INDIVIDUAL APARTMENT CIRCULATION LOOPS

COMMET DEVICE:

COMMET PULSE READING DEVICE FOR REDUCING HOTWATER DELIVERY TIME TO BE SOURCED FROM:

METEORITE MONITORING
1800 848 995
02 9037 7360
info@meteorite.net.au
www.meteorite.net.au

- EQUIPMENT SUPPLIED BY EMBEDDED NETWORKS PER APARTMENT:**
- COMMET DEVICE BY METEORITE MONITORING
 - 2 X HOTWATER METERS

- EQUIPMENT INSTALLED BY EMBEDDED NETWORKS PER APARTMENT:**
- COMMET DEVICE BY METEORITE MONITORING

- EQUIPMENT SUPPLIED BY PLUMBER PER APARTMENT:**
- CARTRIDGE STYLE AUTOMATIC BALANCING VALVE SUPPLIED BY METEORITE MODEL: COMMET-ABV-15-29. EXACT FLOW RATE 0.029L/S
 - PIPEWORK AND ASSOCIATED VALVES

- EQUIPMENT INSTALLED BY PLUMBER PER APARTMENT:**
- CARTRIDGE STYLE AUTOMATIC BALANCING VALVE SUPPLIED BY METEORITE MODEL: COMMET-ABV-15-29. EXACT FLOW RATE 0.029L/S
 - 2 X HOTWATER METERS
 - PIPEWORK AND ASSOCIATED VALVES

